

E CLEARANCE FOR BASKET REMOVAL

NO.	PART NAME	MATERIAL
1	VENT VALVE	GLASS-FILLED PPL
2	COVER	GLASS-FILLED PPL
3	BODY	GLASS-FILLED PPL
4	BASKET	GLASS-FILLED PPL
5	DRAIN PLUG	GLASS-FILLED PPL
* 6	PLUG	GLASS-FILLED PPL
7	O-RING	VITON
8	BAG RETAINER	GLASS-FILLED PPL
9	O-RING	VITON


* IF REQ'D

NOTES:

1. PRESSURE RATING: 150 PSI @ 70° F (NON SHOCK) (10.3 BAR @ 21° C)
2. VENT GAUGE AND DIFFERENTIAL PRESSURE GAUGE ARE OPTIONAL.
3. PIPING CONNECTION (NOM.): 2" NPT (50MM) DRAIN CONNECTION (NOM.): 2" NPT (50MM)
4. BAG SIZES:
 BAG #1-SINGLE LENGTH
 7" X 16" (2.0 SQ.FT.)
 178 MM X 406 MM (1858 SQ.CM.)
 BAG #2-DOUBLE LENGTH
 7" X 32" (4.1 SQ.FT.)
 178 MM X 813 MM (3809 SQ.CM.)
5. FOR METAL PIPING INSTALLATION, A MINIMUM OF 20" PLASTIC PIPE IS REQUIRED ON UPSTREAM AND DOWNSTREAM OF FILTER VESSEL.

CERTIFIED FOR:
 P.O. NO.:
 REG. NO.:
 QUOTE NO.:
 TAG NO.:

PART NO.	A		B		C		D		E		F		G		H		WT. (DRY)	
	IN.	MM.	IN.	MM.	IN.	MM.	IN.	MM.	IN.	MM.	IN.	MM.	IN.	MM.	IN.	MM.	LBS.	KG.
FLT4201	6.50	/ 165	10	/ 254	3.25	/ 83	34.12	/ 867	20	/ 508	18.38	/ 467	6.13	/ 156	23.88	/ 607	49	/ 22.3
FLT4202	6.50	/ 165	10	/ 254	3.25	/ 83	50.12	/ 1273	36	/ 914	18.38	/ 467	6.13	/ 156	39.88	/ 1013	63	/ 28.6



FACTORY DIRECT PIPELINE PRODUCTS, INC.
<http://www.fdpp.com>

NAME
 POLYLINE BAG FILTER
 NPT THREADED CONNECTION
 SIZE 2" POLYPROPYLENE

UNAUTHORIZED USE, MANUFACTURE OR REPRODUCTION IN WHOLE OR IN PART IS PROHIBITED.

DRAWN FM DATE 4/11/95 CERT. WB DATE 4/11/95

SIZE A DWG NO SD021000 REV K

ELECTRONIC FILE NAME: SD021000.DWG
 REF. ECR D507 DATE 1/30/06